



Fire Prevention and Investigation Division

APPENDIX "D"

FIREWORKS STAND INITIAL INSPECTION RECORD

Each fireworks stand must have the following posted:

- State Fire Marshal's license (Original)
- Temporary Seller's Permit from the State Board of Equalization
- Certificate of Insurance
- Name and contact information of two (2) people responsible for the operation of the fireworks stand

The fireworks stand must be at least 10 feet (10') from the following:

- Parking
- Public sidewalk or roadway
- Generators or associated fuel supplies

The fireworks stand must be at least 30 feet (30') from the following:

- Any adjacent buildings
- Property line or burnable materials including dry vegetation
- Fireworks storage container

The fireworks stand must be at least 100 feet (100') from the following:

- Any pump, dispensing device, or fill location for flammable and/or combustible liquids and/or gases

Other fireworks stand requirements:

- Each stand will have a minimum of two (2) exits on opposite sides, each with a minimum thirty-two inch (32") wide clear width.
- Only electric lights may be used and the wiring shall meet the minimum requirements of the California Electrical Code. Open splices are prohibited and all wiring must be protected from physical damage and weather (i.e., bulb cages.) NO "Christmas" lights shall be used in or around the fireworks stands.
- Red lettered "NO SMOKING" signs (in both English and Spanish) shall be located on all sides of the stand.
- One (1) approved 2A:10B:C portable fire extinguisher must be in the fireworks stand sale area and must be serviced within the last year.
- Fireworks signs shall be limited and affixed to the fireworks stands. These signs shall not be placed on public sidewalks, landscape setbacks, or create a traffic hazard. Pennant flags are the only acceptable decorations approved for above and attached to the firework stands. **SANDWICH BOARDS ARE NOT ALLOWED.**
- All persons within the fireworks stand or employed in the sales must be at least eighteen (18) years of age.
- Stands may not obstruct any handicapped parking stall.
- Tarps and canopies shall not be within two feet (2') of a fireworks stand.